

AUTHORIZATION TO MARK

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report(s). This authorization also applies to the Multiple Listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The Certification Mark(s) may be applied only at the location of the Party Authorized to Apply Mark.

Applicant: McKeon Rolling Steel Door Company, Inc. dba McKeon Door Company
44 Sawgrass Drive
Bellport, NY 11713
United States

Contact: Andrew Lambridis

Phone: 631-803-3000

Fax: 631-803-3030

Email: lambridis@mckeondoors.com

Party Authorized to Apply Mark: See following page(s)


Evaluation Center: Intertek (Middleton)

Client Number: 203843

CONFIDENTIAL
PROPERTY OF McKEON

Authorized By: 
Jean-Philippe Kayl, Director of Certification

Intertek Testing Services NA, Inc.
545 E. Algonquin Road, Ste H., Arlington Heights, IL 60005 USA
Phone: 847-439-5667 Fax: 847-439-7320



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Testing Standard(s):	UL 1784 (2009), NFPA 252 (2012), CAN / ULC S104 (2015), UL 10(b) (R2015)
Product:	McKeon Horizontal Rolling Steel Fire and Smoke Shutter

ATM for Report: J9907911, 3103062, 100741416MID-001,
100904711-001R3, Letter Report Q500587810, 102273405MID-001

ATM Issue Date: 4/23/2020

Listing Section(s): DOORS - ROLLING STEEL
SMOKE CONTROL DOOR ASSEMBLIES

CSI Code(s): 08 11 00 Metal Doors and Frames
08 30 00 Specialty Doors and Frames

CONFIDENTIAL
PROPERTY OF McKEON

Description:

DOORS - ROLLING STEEL

Horizontal Rolling Steel Fire and Smoke Shutter for installation in 2 hour locations in masonry or concrete openings or attached to steel beams, provided that the steel beams and the steel supporting members are either completely encased in concrete or completely coated with listed fireproofing material. May be installed with approved smoke seal.

SIZE LIMITATIONS

Certification Procedure	Maximum Area	Maximum Width	Maximum Length
LABEL	200 sq ft	12'-0"	16'-8"
CERTIFICATE/LABEL	unlimited*	unlimited*	unlimited*

CODE COMPLIANCE RESEARCH REPORT

Evaluation Method	Building Code	CCRR Number
NFPA 252, UL 10B, UL 10C, CAN/ULC S104, and UL 1784	2018, 2015, and 2012 IBC 2018, 2015, and 2012 IFC 2017 FBC (Section 9) 2013 Abu Dhabi International Building Code	CCRR-1086

*The AHJ may approve "oversize" doors with no size limitation based on an oversized certificate/label that states the door supplied is constructed in accordance with the certified design except for the size.

Building Codes currently do not address the use of fire rated barriers in horizontal openings other than fire rated floor doors evaluated per NFPA 288. However, in some situations where the installation or availability make the use of such products impractical, horizontal fire and smoke control barriers may be an acceptable alternative. Intertek has successfully tested and evaluated the listed product to NFPA 252, UL 10B with hose stream and CAN4-S104 with the fire and smoke control rated barrier tested in a horizontal orientation. AHJ's should be consulted to determine the acceptability of these products.

Party(s) Authorized by Manufacturer To Apply Mark:

McKeon Rolling Steel Door Company, Inc. dba
McKeon Door Company
44 Sawgrass Drive
Bellport, NY 11713
United States
Contact: Andrew Lambridis
Phone: 631-803-3000
Fax: 631-803-3030
Email: lambridis@mckeondoors.com

Party(s) Authorized by Other Parties To Apply Mark:

None

CONFIDENTIAL
PROPERTY OF McKEON