



LISTING INFORMATION OF

McKeon Series AC8000 Accordion Fire Door Systems With or Without Integral Proprietary Swing Doors

SPEC ID: 29542

McKeon Door Company
44 Sawgrass Drive
Bellport, NY 11713
United States

CONFIDENTIAL
PROPERTY OF McKEON

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

LISTING INFORMATION

FIRE RESISTANT PRODUCTS & COMPONENTS

DOORS - ROLLING STEEL

Accordion Fire Door System, Series AC8000. May incorporate vision panels. May contain integral proprietary swing doors. For installation in gypsum wall or masonry construction.

Alternate Bi-Parting Door Configuration: An alternate bi-parting door configuration consisting of a McKeon Series S4000, S9000 and S7000 Side Coiling and Side Acting Steel Fire Door and a McKeon Series AC8000 Accordion Fire Door is allowed. The McKeon Door Series with the most stringent restrictions and limitations, including size, will be applied for this alternate bi-parting door configuration.

Rating - Maximum 3 Hours

SIZE LIMITATIONS

Certification Procedure	Maximum Area	Maximum Width	Maximum Height
LABEL	130 sq ft	13'-0"	10'-0"
CERTIFICATE/LABEL	unlimited*	unlimited*	unlimited*

CONFIDENTIAL
PROPERTY OF McKEON

CODE COMPLIANCE RESEARCH REPORT

Evaluation Method	Building Code	CCRR Number
NFPA 252, UL 10B, UL 10C, CAN/ULC S104, and UL 1784	2018, 2015, and 2012 IBC 2018, 2015, and 2012 IFC 2017 FBC (Section 9) 2013 Abu Dhabi International Building Code (ADIBC)	CCRR-1086

*The AHJ may approve "oversize" doors with no size limitation based on an oversized certificate/label that states the door supplied is constructed in accordance with the certified design except for the size.

Compliant with Horizontal sliding door means of egress criteria of 2009 and 2012 IBC Section 1008.1.4.3

Attribute	Value
Code Reports	Yes
Criteria	UL 1784 (2009)
Criteria	NFPA 252 (2012)
Criteria	UL 1784 (2015)
Criteria	CAN / ULC S104 (2015)
Criteria	UL 10(b) (R2015)
CSI Code	08 11 00 Metal Doors and Frames
CSI Code	08 30 00 Specialty Doors and Frames
CSI Code	08 35 13.23 Accordion Folding Fire Doors
Fire Resistance	3 Hour Fire Rated
Intertek Services	Certification
Intertek Services	Code Compliance Research Report

Listed or Inspected	LISTED
Listing Section	DOORS - ROLLING STEEL
Listing Section	SMOKE CONTROL DOOR ASSEMBLIES
Report Number	J20008108-231, J20008096-231, J99017990-231, 3095113, 100904711-001R3, 102824676MID-001, 102875787MID-001
Spec ID	29542
Verification Testing	No

CONFIDENTIAL
PROPERTY OF McKEON