

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 3515-1515:0107 Page 1 of 1

**CATEGORY:** 3515 -- ROLLING STEEL DOOR (FIRE-RATED)

**LISTEE:** MCKEON ROLLING STEEL DOOR CO44 SAWGRASS DRIVE, BELLPORT, NY 11713  
Contact: Andrew Lambridis (631) 803-3000 Fax (631) 803-3030  
Email: lambridis@mckeondoor.com

**DESIGN:** Models S7200, S7400, & S7500 manually operated and S7600, S7700, & S7900 motor operated side acting fire door consisting of vertical cold rolled interconnected steel or stainless steel slats and may incorporate integral proprietary swing doors. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 3 hrs.

**INSTALLATION:** In accordance with listee's printed installation instructions, NFPA 80, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, Model number, classification and Intertek label.

**APPROVAL:** Listed as a side acting fire door. Maximum size 13.5' wide x 10' high. Refer to listee's Installation Instruction Manual for details.

5-5-16 dc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2019**

Listing Expires **August 29, 2020**

Authorized By: **DAVID CASTILLO, Program Coordinator**  
*Fire Engineering Division*