

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 3261-1515:0103 Page 1 of 1

CATEGORY: 3261 -- FOLDING DOOR (FIRE-RATED)

LISTEE: MCKEON ROLLING STEEL DOOR CO44 SAWGRASS DRIVE, BELLPORT, NY 11713
Contact: Andrew Lambridis (631) 803-3000 Fax (631) 803-3030
Email: lambridis@mckeondoor.com

DESIGN: Modesl AC8200, AC8400, AC8500, AC8600, AC8700, AC8800, & AC8900, horizontal accordion sliding fire door. Door is constructed of 18 guage, 7" or 14" wide flat accordion panel. Neoprene sheets are located top and bottom. Door may incorporate vision panels and integral proprietary swing doors. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 3 hr.

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 80, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, Model number, classification and Intertek label.

APPROVAL: Listed as an accordion fire door for installation in gypsum wall or masonry construction. Maximum size 13' wide x 10' high. Refer to listee's Installation Instruction Manual for details.

6-17-16 dc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2020**

Listing Expires **June 30, 2021**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**
Fire Engineering Division