

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 4077-1515:0108 Page 1 of 1

CATEGORY: 4077 -- FIRE PROTECTIVE CURTAIN

LISTEE: MCKEON ROLLING STEEL DOOR CO44 SAWGRASS DRIVE, BELLPORT, NY 11713
Contact: Andrew Lambridis (631) 803-3000 Fax (631) 803-3030
Email: lambridis@mckeondoor.com

DESIGN: Models D200 and D200E Fabric curtains. D200E may incorporate passage doors. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: See Approval

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 80, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, Model number, classification and Intertek label.

APPROVAL: Listed as a fabric curtain for the following: Fire resistance 20 min. without Hose Stream Test Negative Pressure, Fire Resistance 20 min. without Hose Stream Test Positive Pressure or 3 hour Positive Pressure. Approval from the AHJ shall be obtained prior to installation. Refer to listee's Installation Instruction Manual for details.

1-26-16 jp



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2020**

Listing Expires **June 30, 2021**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**
Fire Engineering Division