



LISTING INFORMATION OF
McKEON MCK3200 and MCK4415 Curtain Fabrics
SPEC ID: 68225

McKEON
44 Sawgrass Drive
Bellport, NY 11713
United States

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

LISTING INFORMATION

The MCK3200 and MCK4415 curtain fabrics are used in the construction of McKEON Smoke and Draft and/or Fire Protective curtain assemblies. Material properties and flame spread ratings for each fabric are detailed below.

MATERIAL PROPERTIES - MCK3200

Material Property	Description
Finished Weight	13.4 oz/yd ² (455 g/m ²)
Finished Thickness (nominal)	16 mils (0.40 mm)
Base Fabric	Fiberglass
Weave	4 Shaft Satin
Warp & Weft (1/cm)	18.6 x 11
Finishing/Coating	Aluminum pigmented polyurethane
ASTM E84 Flame Spread Index (FSI)	<25
ASTM E84 Smoke Developed Index (SDI)	<450

MATERIAL PROPERTIES - MCK4415

Material Property	Description
Finished Weight	18.9 oz/yd ² (640 g/m ²)
Finished Thickness (nominal)	21 mils (0.54 mm)
Base Fabric	Stainless steel reinforced fiberglass
Weave	8 Shaft Satin
Warp & Weft (1/cm)	16 x 15.3
Finishing/Coating	Aluminum pigmented polyurethane
ASTM E84 Flame Spread Index (FSI)	<25
ASTM E84 Smoke Developed Index (SDI)	<450

Attribute	Value
Criteria	ASTM E84 (2021)
CSI Code	07 80 00 Fire and Smoke Protection
CSI Code	07 87 00 Smoke Containment Barriers
Intertek Services	Certification
Listed or Inspected	LISTED
Listing Section	SPECIALTY FIRE/DOOR & FRAME ASSEMBLIES & COMPONENTS
Spec ID	68225