



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	3515-1515:0101
<b>CATEGORY:</b>	3515 - ROLLING STEEL DOOR (FIRE-RATED)
<b>LISTEE:</b>	MCKEON ROLLING STEEL DOOR CO 44 SAWGRASS DRIVE, BELLPORT, NY,11713 Contact: Lambridis,Andrew (631) 803-3030 Email: lambridis@mckeondoor.com
<b>DESIGN:</b>	Model Safescape S9000 horizontal sliding, side coil, slat type, special purpose steel fire door with integral side swinging steel door assemblies. The door curtain is side activated and is designed to travel in a horizontal or inclined plane. Unit is an assembled from interlocking galvanized steel slats (minimum 20 gauge G-90 galvanized steel). Refer to listee's data sheet for additional detailed product description and operational considerations..
<b>RATING:</b>	
<b>INSTALLATION:</b>	In accordance with listee's printed installation instructions, NFPA 80, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.
<b>MARKING:</b>	Listee's name, Model number, classification and UL label.
<b>APPROVAL:</b>	Listed as fire-rated rolling steel doors for use to protect openings in masonry or drywall construction walls up to and including 3 Hours location. Maximum size of openings:  13.5'W x 10'H  For doors exceeding <u>above dimensions</u> are considered oversize doors and are not covered under this listing. The design of these doors is based upon, and is similar to, the approval product design but they have not been subject to approval testing due to test facility limitations. Acceptance of these doors is the <u><i>prerogative of the authority having jurisdiction.</i></u>
<b>NOTES:</b>	

09-23-98



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 03/14/2023**

**Listing Expires: 06/30/2024**



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

Authorized By: **Victor Wong**, Program Coordinator  
Fire Engineering & Investigations Division