



LISTING INFORMATION OF  
**McKEON Series T2000/T5000/TU5000 Vertical Rolling Steel  
Fire Door with Integral Proprietary Swing Doors**  
SPEC ID: 29544

McKEON  
44 Sawgrass Drive  
Bellport, NY 11713  
United States

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

## LISTING INFORMATION

### FIRE RESISTANT PRODUCTS & COMPONENTS

#### DOORS - ROLLING STEEL

##### Product Covered

Series T2000/T5000/TU5000\*.

##### Product Description

**Non-insulated:** Vertical rolling steel fire door assembly with integral swinging doors for installation in gypsum and structural steel stud, gypsum-protected CLT (see limitations below), or masonry construction. May incorporate vision panels.

Fire Resistance Rating: 3 Hour

**Insulated:** Vertical rolling steel fire door assembly with integral swinging doors for installation in gypsum and structural steel stud, gypsum-protected CLT (see limitations below), or masonry construction. May incorporate vision panels.

Fire Resistance Rating: 3 Hour

##### Temperature Rise Ratings:

- 650 degree Fahrenheit maximum temperature rise rating at 30 minutes when used singly in a masonry, gypsum-protected CLT (see limitations below), or drywall and structural steel stud opening.
- Please note, if an Integral Proprietary Swinging Door is used in conjunction with the McKeon Series T2000, T5000 or TU5000 Vertical Rolling Steel Fire Doors, the integral swinging doors must also bear a temperature rise rating equal to or better than the respective temperature rise ratings noted above.
- Fire Resistance Rating: 90 Minutes (Unit Used Singly)

\*TU5000 pair swinging doors require 4 point latching.

### AIR LEAKAGE RATINGS

Test Standard	Test Type	Rating <sup>a</sup>
UL 1784	Ambient Temperature	≤3.0 cfm/ft <sup>2</sup> at up to 0.10 in. of w.c.
UL 1784	Elevated Temperature	≤3.0 cfm/ft <sup>2</sup> at up to 0.10 in. of w.c.

<sup>a</sup>These assemblies were evaluated **without the use of an artificial bottom seal**. When installed with the manufacturer-provided brushes and neoprene bottom seal, they may be installed in areas where pressurization is provided to control smoke movement in accordance with Section 4.3.2 of NFPA 105 and for hoistway opening protection and lobby doorways as allowed in Chapter 30 of the IBC. For installations exclusive of hoistway opening protection and lobby doorways, and where pressurization is not used to control smoke movement, seals at the bottom edges of the assemblies are optional.

### CODE COMPLIANCE RESEARCH REPORT

Evaluation Method	Building Code	CCRR Number
-------------------	---------------	-------------

NFPA 252	2021, 2018, and 2015 IBC	CCRR-1086
UL 10B	2021, 2018, and 2015 IFC	
UL 1784	2023, 2020 FBC	

### SIZE LIMITATIONS

Certification Procedure	Maximum Area	Maximum Width	Maximum Height
LABEL	156 sq ft	13'-0"	12'-0"
CERTIFICATE/LABEL	unlimited*	unlimited*	unlimited*

\*The AHJ may approve "oversize" doors with no size limitation based on an oversized certificate/label that states the door supplied is constructed in accordance with the certified design except for the size.

### INSTALLATION LIMITATIONS

Assemblies may be installed in gypsum with structural steel stud, masonry, or gypsum-protected Cross Laminated Timber (CLT) walls. When installed in gypsum-protected CLT walls, the following conditions apply:

- Supporting CLT wall must be fire-resistance-rated in accordance with the code.
- Noncombustible protection shall be in accordance with the code, but not less than:
  - Two layers of 5/8-inch Type X gypsum per face for walls required to have a fire-resistance rating of 2 hours or less.
  - Three layers of 5/8-inch Type X gypsum per face for walls required to have a fire-resistance rating of 3 hours or more.
- Assemblies bearing a fire-protection rating of 90 minutes or less shall be designed with an additional sacrificial 1 inch of anchorage embedment depth or be through-bolted.
- Assemblies bearing a fire-protection rating of 2 or 3 hours shall use through-bolted anchorage.

Attribute	Value
Certificate Date of Expiry	December 31, 2023
Certificate Date of Initial Registration	March 29, 2019
Certificate Number	WHI19-20384303
Code Reports	Yes
Criteria	NFPA 252 (2012)
Criteria	UL 1784 (2015)
Criteria	CAN / ULC S104 (2015) (R2020)
Criteria	UL 10(b) (2008) (R2015)
CSI Code	08 11 00 Metal Doors and Frames
CSI Code	08 30 00 Specialty Doors and Frames
CSI Code	08 35 13.23 Accordion Folding Fire Doors
Fire Resistance	3 Hour Fire Rated
Fire Resistance	90 Minute Fire Rated
Intertek Services	Certification
Intertek Services	Code Compliance Research Report

Issue Status	6
Listed or Inspected	LISTED
Listing Section	DOORS - ROLLING STEEL
Listing Section	SMOKE CONTROL DOOR ASSEMBLIES
Report Number	14376-231, 3064271, 3095113, 3188620, 100506561, 100904711, 102273405, 105476021
Spec ID	29544
Temperature Rise	@ 30 Min = 650° F MAX Where Lites Do Not Exceed 100 IN2
Verification Testing	No