


# Smoke and Fire Curtain Egress Feature

- 1 Curtain assembly retracted in headbox.



- 2 Curtain assembly deployed.




- 4 28 lbs. of force or less required to put the egress door in motion.

- 5 Egress Signage

- 6 ADA Compliant Threshold

- 7 Stainless Steel Hook & Loop Fastener



- 8 1/2 lb of force required to open egress door fully.



- 9 Pivoting Bottom Bar ensures egress door closure



- 10 Vision Panel

- 11 Egress door must be fully closed and bottom bar fully engaged prior to curtain opening.

