

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL FIRE ENGINEERING & INVESTIGATIONS DIVISION BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

| LISTING No.: | 3515-1515:0102 |
|---------------|---|
| CATEGORY: | 3515 - ROLLING STEEL DOOR (FIRE-RATED) |
| LISTEE: | MCKEON ROLLING STEEL DOOR CO 44 SAWGRASS DRIVE, BELLPORT, NY, 11713 Contact: Lambridis, Andrew (631) 803-3000 (631) 803-3030 Email: lambridis@mckeondoor.com |
| DESIGN: | Model FSFD rolling steel fire door assemblies. Unit is an assembled from interlocking galvanized steel slats (minimum 20 gauge G-90 galvanized steel). Refer to listee's data sheet for additional detailed product description and operational considerations. |
| RATING: | 3hr |
| INSTALLATION: | In accordance with listee's printed installation instructions, NFPA 80, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. |
| MARKING: | Listee's name, Model number, classification and UL label. |
| APPROVAL: | Listed as fire-rated rolling steel doors for use to protect openings in walls up to and including 3 Hours location. Rolling steel fire doors maximum size of openings: 13'W x 11'H Maximum Area 144 sq. ft. For doors exceeding <u>above dimensions</u> and <u>144 sq. ft in area</u> are considered oversize doors and are not cover under this listing. The design of these doors is based upon, and is similar to, the approval product design but they have not been subject to approval testing due to test facility limitations. Acceptance of these doors is the <u>prerogative of the authority having jurisdiction</u> . |
| NOTES: | |

09/23/1998



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 03/26/2025 Listing Expires: 06/30/2026



CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL FIRE ENGINEERING & INVESTIGATIONS DIVISION BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

| Authorized By: Michael Huang , Program Coordinator Fire Engineering & Investigations Division | | |
|--|--|--|
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |