



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	3515-1515:0106
CATEGORY:	3515 - ROLLING STEEL DOOR (FIRE-RATED)
LISTEE:	MCKEON ROLLING STEEL DOOR CO 44 SAWGRASS DRIVE, BELLPORT, NY, 11713 Contact: Lambridis, Andrew (631) 803-3000 (631) 803-3030 Email: lambridis@mckeondoor.com
DESIGN:	Model T5000 Vertical coiling fire door incorporating integral proprietary swing doors. Refer to listee's data sheet for additional detailed product description and operational considerations.
RATING:	3 hrs.
INSTALLATION:	In accordance with listee's printed installation instructions, NFPA 80, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, Model number, classification and Intertek label.
APPROVAL:	Listed as a vertical coiling fire door. Maximum size 13' wide x 12' high. Refer to listee's Installation Instruction Manual for details.
NOTES:	

3-22-16 dc



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 03/26/2025

Listing Expires: 06/30/2026

Authorized By: **Michael Huang**, Program Coordinator
Fire Engineering & Investigations Division