



LISTING INFORMATION OF
McKEON BT1000 Bullet Resistant Door
SPEC ID: 77898

McKEON
44 Sawgrass Drive
Bellport, NY 11713
United States

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

LISTING INFORMATION

McKEON BT1000 Bullet Resistant Door

BULLET RESISTANCE RATING

Test Standard	Rating
UL 752 (11 th Edition)	Level 1

FORCED ENTRY RESISTANCE RATING^a

Test Standard	Maximum Size	Rating
ASTM F3038	20'-3-1/2" wide 18'-0" high	60 Minutes

^aWidth is tip to tip of support guide angles

INSTALLATION LIMITATIONS

Assemblies must be installed on the protected (non-attack) face of the supporting wall

When mounted to steel supporting structure, Mounting Angles are anchored with minimum 5/8" diameter A325 bolts spaced maximum 12 inches on-center. Structural adequacy of steel supporting structure is to be determined by others and is not evaluated as part of this Listing.

When mounted to concrete supporting structure, Mounting Angles are anchored with 5/8" diameter wedge anchors spaced maximum 12 inches on-center. Structural adequacy of concrete supporting structure is to be determined by others and is not evaluated as part of this Listing.

Alternate anchoring to supporting structure that maintains the maximum spacing of 12 inches on-center is to be designed by a registered design professional.

Installation shall follow these listing procedures and the manufacturer's instructions provided with each assembly. In the event of a conflict, these listing procedures govern.

Attribute	Value
Criteria	UL 752 (2005) Ed: 11 (2015)
Criteria	ASTM F3038 (2021)
CSI Code	08 34 00 Special Function Doors
Intertek Services	Certification
Listed or Inspected	LISTED
Listing Section	BULLET/FORCED ENTRY RESISTANT PRODUCTS
Report Number	G105738796; Q8598; Q0090; G105901890
Spec ID	77898
Verification Testing	No