



LISTING INFORMATION OF  
**McKEON BT3000 Bullet Resistant Door**  
SPEC ID: 77899

McKEON  
44 Sawgrass Drive  
Bellport, NY 11713  
United States

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

## LISTING INFORMATION

### McKEON BT3000 Bullet Resistant Door

#### BULLET RESISTANCE RATING

| Test Standard                     | Rating  |
|-----------------------------------|---------|
| UL 752 (11 <sup>th</sup> Edition) | Level 3 |

#### FORCED ENTRY RESISTANCE RATING<sup>a</sup>

| Test Standard | Maximum Size                   | Rating     |
|---------------|--------------------------------|------------|
| ASTM F3038    | 20'-3-1/2" wide<br>18'-0" high | 60 Minutes |

<sup>a</sup>Width is tip to tip of support guide angles

#### INSTALLATION LIMITATIONS

Assemblies must be installed on the protected (non-attack) face of the supporting wall

When mounted to steel supporting structure, Mounting Angles are anchored with minimum 5/8" diameter A325 bolts spaced maximum 12 inches on-center. Structural adequacy of steel supporting structure is to be determined by others and is not evaluated as part of this Listing.

When mounted to concrete supporting structure, Mounting Angles are anchored with 5/8" diameter wedge anchors spaced maximum 12 inches on-center. Structural adequacy of concrete supporting structure is to be determined by others and is not evaluated as part of this Listing.

Alternate anchoring to supporting structure that maintains the maximum spacing of 12 inches on-center is to be designed by a registered design professional.

Installation shall follow these listing procedures and the manufacturer's instructions provided with each assembly. In the event of a conflict, these listing procedures govern.

| Attribute                | Value                                  |
|--------------------------|----------------------------------------|
| Criteria                 | UL 752 (2005) Ed: 11 (2015)            |
| Criteria                 | ASTM F3038 (2021)                      |
| CSI Code                 | 08 34 00 Special Function Doors        |
| Intertek Services        | Certification                          |
| Listed or Inspected      | LISTED                                 |
| Listing Section          | BULLET/FORCED ENTRY RESISTANT PRODUCTS |
| Report Number            | G105738796; Q8598; Q0090; G105901890   |
| Spec ID                  | 77899                                  |
| Verification Test Type   | ASTM E1252                             |
| Verification Testing     | YES                                    |
| Verification Testing Lab | MID - Middleton, WI                    |