



LISTING INFORMATION OF

**McKEON SmokeFighter® Model D500S Smoke and Draft
Curtain Assembly with Intermediate Fasteners**

SPEC ID: 53562

McKEON
44 Sawgrass Drive
Bellport, NY 11713
United States

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

LISTING INFORMATION

The McKEON SmokeFighter® Model D500S system is for use as a smoke barrier curtain assembly.

AIR LEAKAGE RATINGS

Test Standard	Test Type	Rating ^a
UL 1784	Ambient Temperature	≤3.0 cfm/ft ² at up to 0.10 in. of w.c.
UL 1784	Elevated Temperature	≤3.0 cfm/ft ² at up to 0.10 in. of w.c.

^aThis assembly was evaluated without the use of an artificial bottom seal and may be installed in areas where pressurization is provided to control smoke movement in accordance with Section 4.3.2 of NFPA 105 (2019) and for hoistway opening protection and lobby doorways as allowed in Chapter 30 of the IBC.

SIZE LIMITATIONS

Minimum Size ^a	Maximum Size ^b
78" tall x 29.5" wide	48'0" tall x 500'0" wide

^aClear opening dimensions (i.e., tip-to-tip width between side guides and drop height below headbox)

^bOversize labels are not required for this assembly. Assembly dimensions must comply with the minimum and maximum values listed above.

CODE COMPLIANCE RESEARCH REPORT

Evaluation Method	Building Code	CCRR Number
UL 1784	2024, 2021, 2018 IBC 2024, 2021, 2018 IFC 2023, 2020 FBC 2022 CBC 2023 LABC 2024, 2021, 2018 NFPA 101	CCRR-0455

The McKEON SmokeFighter Model D500S system comprises a 22-gauge head box, MCK4415 smoke & draft curtain, McKEON 1047 Intermediate Fastener system (when used), 14-gauge side rails, and a 14-gauge bottom bar.

The McKEON Intermediate 1047 Fastener system is used to join vertical edges of multiple MCK4415 fabric panels to create larger panels. The fastener system must be spaced with a minimum of 1 lineal foot of curtain between fasteners.

Minimum Curtain Overlap: 15.75"

Minimum Bottom Bar weight: 0.30 lbs per sq. ft. of curtain area or 3.9 lb/ft of length, whichever is greater

Maximum Curtain Rivet spacing: 15" on-center

Side Guide anchorage: 1/4" anchors spaced maximum 18" on-center

Top Hood/Assembly mounting: maximum 40" on-center

The SmokeFighter Model D500S system must be installed per manufacturer's instructions.

Attribute	Value
Certificate Date of Expiry	December 31, 2025
Certificate Date of Initial Registration	April 23, 2020
Certificate Number	WHI20-20384308
Code Reports	Yes
Criteria	UL 1784 (2015)
CSI Code	08 30 00 Specialty Doors and Frames
Intertek Services	Certification
Intertek Services	Code Compliance Research Report
Issue Status	15
Listed or Inspected	LISTED
Listing Section	SMOKE CONTROL DOOR ASSEMBLIES
Report Number	G100074822, G102718261, G104078807, G104255393, G104986323, G105850951, G105576271
Spec ID	53562
Verification Test Type	ASTM E1252
Verification Testing	YES
Verification Testing Lab	MID - Middleton, WI