



LISTING INFORMATION OF
McKEON AL3014 Rolling Door Assembly
SPEC ID: 84616

McKEON
44 Sawgrass Drive
Bellport, NY 11713
United States

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

LISTING INFORMATION

McKEON AL3014 Rolling Door Assembly

The McKEON AL3014 is a vertically coiling rolling door assembly installed with perimeter seals to reduce air infiltration and exfiltration.

AIR LEAKAGE RATINGS

Test Standards	Direction	Leakage Rate (cfm/ft ²)
ANSI/DASMA 105 (Air Leakage Only) DASMA 112 ASTM E283	Infiltration	0.84
	Exfiltration	0.92

Attribute	Value
Criteria	ASTM E283/E283M (2019)
Criteria	ANSI / DASMA 105:2017
Criteria	DASMA 112 (2023)
CSI Code	08 33 23 Overhead Coiling Doors
Intertek Services	Certification
Listed or Inspected	LISTED
Report Number	G105952574; R7251; R8141
Spec ID	84616
Verification Testing	No