



LISTING INFORMATION OF

## McKEON Series AC8000 Accordion Fire Door Systems With or Without Integral Proprietary Swing Doors

SPEC ID: 29542

McKEON  
44 Sawgrass Drive  
Bellport, NY 11713  
United States

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

## LISTING INFORMATION

### FIRE RESISTANT PRODUCTS & COMPONENTS

#### DOORS - ROLLING STEEL

Accordion Fire Door System, Series AC8000. May incorporate vision panels. May contain integral proprietary swing doors. For installation in gypsum wall or masonry construction.

Alternate Bi-Parting Door Configuration: An alternate bi-parting door configuration consisting of a McKeon Series S4000, S9000 and S7000 Side Coiling and Side Acting Steel Fire Door and a McKeon Series AC8000 Accordion Fire Door is allowed. The McKeon Door Series with the most stringent restrictions and limitations, including size, will be applied for this alternate bi-parting door configuration.

Rating - Maximum 3 Hours

#### AIR LEAKAGE RATINGS

Test Standard	Test Type	Rating <sup>a</sup>
UL 1784	Ambient Temperature	≤3.0 cfm/ft <sup>2</sup> at up to 0.10 in. of w.c.
UL 1784	Elevated Temperature	≤3.0 cfm/ft <sup>2</sup> at up to 0.10 in. of w.c.

<sup>a</sup>These assemblies were evaluated **without the use of an artificial bottom seal**. When installed with the manufacturer-provided brushes and sweeps, they may be installed in areas where pressurization is provided to control smoke movement in accordance with Section 4.3.2 of NFPA 105 and for hoistway opening protection and lobby doorways as allowed in Chapter 30 of the IBC. For installations exclusive of hoistway opening protection and lobby doorways, and where pressurization is not used to control smoke movement, seals at the bottom edges of the assemblies are optional.

#### SIZE LIMITATIONS

Certification Procedure	Maximum Area	Maximum Width	Maximum Height
LABEL	130 sq ft	13'-0"	10'-0"
CERTIFICATE/LABEL	unlimited*	unlimited*	unlimited*

\*The AHJ may approve "oversize" doors with no size limitation based on an oversized certificate/label that states the door supplied is constructed in accordance with the certified design except for the size.

#### CODE COMPLIANCE RESEARCH REPORT

Evaluation Method	Building Code	CCRR Number
NFPA 252	2024, 2021, 2018 IBC 2024, 2021, 2018 IFC 2023, 2020 FBC	
UL 10B	2022 CBC	CCRR-1086
UL 1784	2023 LABC 2022 NYCBC	

Attribute	Value

Certificate Date of Expiry December 31, 2026

Certificate Date of Initial Registration March 19, 2019

Certificate Number WHI19-20384302

Code Reports Yes

Criteria UL 1784 (2015)

Criteria CAN / ULC S104 (2015) (R2020)

Criteria UL 10(b) (2008) (R2015)

Criteria NFPA 252 (2022)

CSI Code 08 11 00 Metal Doors and Frames

CSI Code 08 30 00 Specialty Doors and Frames

CSI Code 08 35 13.23 Accordion Folding Fire Doors

Fire Resistance 3 Hour Fire Rated

Intertek Services Certification

Intertek Services Code Compliance Research Report

Issue Status 13

Listed or Inspected LISTED

Listing Section DOORS - ROLLING STEEL

Listing Section SMOKE CONTROL DOOR ASSEMBLIES

Report Number J20008108-231, J20008096-231, J99017990-231, 3095113, G100904711, G102824676, G102875787, G105502242, G105850951, G106354797

Spec ID 29542

Verification Testing No