



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	4077-1515:0108
<b>CATEGORY:</b>	4077 - FIRE PROTECTIVE CURTAIN
<b>LISTEE:</b>	MCKEON ROLLING STEEL DOOR CO 44 SAWGRASS DRIVE, BELLPORT, NY, 11713 Contact: Lambridis, Andrew (631) 803-3000 (631) 803-3030 Email: lambridis@mckeondoor.com
<b>DESIGN:</b>	Models D200 and D200E Fabric curtains. D200E may incorporate passage doors. Refer to listee's data sheet for additional detailed product description and operational considerations.
<b>RATING:</b>	See Approval
<b>INSTALLATION:</b>	In accordance with listee's printed installation instructions, NFPA 80, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.
<b>MARKING:</b>	Listee's name, Model number, classification and Intertek label.
<b>APPROVAL:</b>	Listed as a fabric curtain for the following: Fire resistance 20 min. without Hose Stream Test Negative Pressure, Fire Resistance 20 min. without Hose Stream Test Positive Pressure or 3 hour Positive Pressure. Approval from the AHJ shall be obtained prior to installation. Refer to listee's Installation Instruction Manual for details.
<b>NOTES:</b>	

1-26-16 jp



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 03/20/2026**

**Listing Expires: 06/30/2027**

Authorized By: **Michael Huang**, Program Coordinator  
Fire Engineering & Investigations Division