



# FDNY

**BUREAU OF FIRE PREVENTION**

**9 Metro Tech Center, 3rd Floor**

**Brooklyn, NY, 11201**

To: Magid Shata  
From: New York City Fire Department  
Date: Mar 25, 2026  
Record ID: 2025-TMCPTD-007721-DOCU



Premises Address: City-Wide

BIN

Application Type: Engineering Application

Result: Letter of No Objection

Dear Mr. Shata:

This is in receipt of your submission on behalf of McKeon in conjunction with the Office of Technical and Certification Research (OTCR) application for review of the Curtain Fire Shutter Model FireFighter D400 for use throughout New York City. You indicate that the fire shutter has been tested in accordance with UL10B and UL 1784 by Intertek laboratories (CCRR-1086) and achieved a ninety minute fire rating.

The McKeon D400 vertical rolling fire and smoke curtain shutter units consist of a rolling curtain panel made by permanently joining textile layers, a barrel and headbox above the opening, and side guides. They are recognized for installation in light-gage steel framed gypsum or masonry wall openings.

Please be advised that the New York City Fire Department reviewed your submission and has no objection to the New York City Department of Buildings OTCR's approval of the horizontal fire shutter upon the following conditions:

1. The fire shutters and their installation shall comply with all applicable requirements of the 2022 New York City Construction Codes (including the Building Code), the rules (including New York City Department of Buildings rule, 1 RCNY Section 101-12), and the manufacturer's design and installation manual and the listing of the product.
2. The installation of the fire shutters shall be approved by the NYC Department of Buildings.
3. Open protectives shall comply with the requirements of BC 716, including fire shutter assemblies as set forth in BC 716.5.
4. Materials and methods of construction used to protect joints and penetrations in fire-resistance- rated building elements, components or assemblies shall not reduce the required fire-resistance rating per BC 705.8.

When responding to this Department regarding this subject matter, kindly refer to 2025-TMCPTD-007721-DOCU and to the



# FDNY

**BUREAU OF FIRE PREVENTION**

**9 Metro Tech Center, 3rd Floor**

**Brooklyn, NY, 11201**

attention of Jenna Nixon, who can be reached at (718) 999-1516 or [jenna.nixon@fdny.nyc.gov](mailto:jenna.nixon@fdny.nyc.gov).

KC: JN

CC: Alan Price, P.E., Director of OTCR, NYC Department of Buildings

By Order of,  
Chief of Fire Prevention