



LISTING INFORMATION OF
**McKeon D400X 120 Minute Opening Protective Assembly
with Hose Stream**
SPEC ID: 92290

McKEON
44 Sawgrass Drive
Bellport, NY 11713
United States

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

LISTING INFORMATION

McKeon Model D400X 120 Minute Opening Protective Assembly with Hose Stream with optional curtain overlap.

FIRE RATINGS

Test Standard	Rating ^a
UL 10B, NFPA 252, CAN/ULC S104	120 minutes with hose stream

^aAssembly must be installed in a listed steel stud/gypsum or masonry wall matching or exceeding the desired door rating.

MAXIMUM SIZE LIMITATIONS

Certification Procedure	Area	Width	Height
LABEL*	120 sq ft	12' 0"	10' 0"
OVERSIZE CERTIFICATE/LABEL	Unlimited	Unlimited	Unlimited

*Assemblies exceeding these dimensions must have an oversize label, issued by Intertek, stating the assembly is constructed in accordance with the certified design except for size. Acceptance of the oversize assembly is at the discretion of the Authority Having Jurisdiction.

INSTALLATION LIMITATIONS

Assemblies may be installed in gypsum with structural steel stud or masonry walls.

Minimum Bottom Bar weight: 3.6 lbs per ft. of bottom bar or 0.3 lbs per sq ft. of curtain area
Minimum 23-5/8" optional curtain overlap allowed.

Side Guide Anchorage: 1/4" anchors spaced maximum 18" on-center
Top Hood/Assembly Mounting: maximum 24" on-center

Attribute	Value
Criteria	CAN / ULC S104 (2015) (R2020)
Criteria	UL 10(b) (2008) (R2015)
Criteria	NFPA 252 (2017)
Criteria	UL 10(b) (2008) (R2020)
Criteria	NFPA 252 (2022)
CSI Code	08 30 00 Specialty Doors and Frames
Fire Resistance	2 Hour Neutral Pressure
Intertek Services	Certification
Listed or Inspected	LISTED
Listing Section	MISCELLANEOUS FIRE BARRIERS
Report Number	G106480432
Spec ID	92290

Verification Test Type ASTM E1252
Verification Testing YES
Verification Testing Lab MID - Middleton, WI